



Lamond RC Lead in Water Test Results

FY21 Filter Test

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|-------------|-----------------------|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS- 005370 | 4/9/2021 | 4/9/2021 | 1 | Cooler | In fitness center 131 | WF-04092021-005370 | 6/8/2021 | FT-FY21-022021-005370-A | <1 | FT-FY21-022021-005370-B | <1 |
| WS- 005371 | 4/9/2021 | 4/9/2021 | 1 | Cooler | In fitness center 131 | WF-04092021-005371 | 6/8/2021 | FT-FY21-022021-005371-A | <1 | FT-FY21-022021-005371-B | <1 |

Food Prep Sink

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|----------------|-----------------|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS- 005369 | 2/23/2021 | 2/23/2022 | 1 | Food Prep Sink | In kitchen 129 | WF-02232021-005369 | 6/8/2021 | FT-FY21-022021-005369-A | <1 | FT-FY21-022021-005369-B | <1 |